

Question 1.

All construction areas and the front form of Office 2 (TDY) will not be available during the construction period, is this correct

Answer 1.

Yes, the rooms will not be occupied during construction.

Question 2.

Will it be ok if the new door is not a Dutch door?

Answer 2.

Yes, the new door must be a regular door.

Question 3.

Does the new door need a key?

Answer 3.

Yes, the new door needs a key.

Question 4.

Is it okay to use the remote-control type that was used in Office 3 for the dimmer lights?

Answer 4.

Yes, please use the same type.

Question 5.

If there are beams in the basement, will it be okay to install the air conditioner on the new wall?

Answer 5.

If the new wall can withstand the weight, yes, however, the final location for the AC will be decided by the COR.

Question 6.

Is it okay to have covers using slim duct made of PVC?

Answer 6.

Yes, if they are made of good quality materials that matches well with the office interior.

Question 7.

Please specify the new furniture in detail. What kind of furniture do you need and how many?

Answer 7.

One 180 x 60cm working space desk with drawers.